

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/07/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 154020		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 8555 TAFT ST B. WING _____		(X3) DATE SURVEY COMPLETED R 06/04/2012	
NAME OF PROVIDER OR SUPPLIER REGIONAL MENTAL HEALTH CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 8555 TAFT ST MERRILLVILLE, IN 46410			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 04/20/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 482.41(b).</p> <p>Survey Date: 06/04/12</p> <p>Facility Number: 005184 Provider Number: 154020 AIM Number: 100273350A</p> <p>Surveyor: Dennis Austill, Life Safety Code Supervisor</p> <p>At this PSR survey, Regional Mental Health Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 482.41(b), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies.</p> <p>This two story facility was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and in patient sleeping rooms. The In-Patient Unit located on the second floor has a capacity of 16 and had a census of 12 at the time of this survey.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 06/05/12.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.